

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8140-2255:0500 Page 1 of 1

CATEGORY: 8140 -- EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)

LISTEE: The Tapco Group 200 Shotwell Drive, Franklin, OH 45005
Contact: Rita Scramlin (248) 668-7954
Email: Rita_Scramlin@tapcoint.com

DESIGN: Grayne Engineered composite polyvinyl chloride (PVC) exterior siding material, 5" and 7-1/2" width, mounted to wall structure over 1/2" type X gypsum board studs with #8 X 1-1/4" fasteners at every stud location, manufactured using a sheet extrusion process to simulate a natural cedar siding. Refer to the manufacturer's installation instructions and product data sheets.

RATING: Compliance in accordance with SFM Standard 12-7A-1, 2016 California Referenced Standards Code

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee name, Model number, rating and SFM label.

APPROVAL: Listed as exterior siding for use in the Wildland Urban Interface areas.

10--10-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division